

**Certificate Number:** AZ 69021254

Page: 0026



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV021254E

CONTINUATION SHEET 25

(Modification 6)

1. Add models: GW3000T-DS , GW3600T-DS , GW4200T-DS , GW5000T-DS

2. New models are simialr to previous certified models, except:

- a. Add AFCI circuit, increase AFCI detection function;
- b. Maximum input current increased to 13/13A;
- c. Maximum short circuit current increased to 16.3/16.3A.

output power and current ratings:

GW3000T-DS: max apparent power: 3000VA; lac max: 13.6A

GW3600T-DS: max apparent power: 3680VA; lac max: 16A

GW4200T-DS: max apparent power: 4200VA; lac max: 19A

GW5000T-DS: max apparent power: 5000VA; lac max: 22.8A

Issue Date: 27/04/2021

Expiry Date: 19/08/2021

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)