

CERTIFICATE OF COMPLIANCE

By the product certificate number

No. 2620/0404-CER

Issued to:

Manufacturer **Jiangsu GoodWe Power Supply Technology Co., Ltd.**
 No.90 Zijin Rd., New District, Suzhou, 215011, China



Trademark



It is certified that the product:

Type of product **Hybrid Inverter**

Models	GW0010-EHB	GW8600-EHB	GW6500-EHB	GW5000-EHB
Technical data				
Rated Power	10000 W	8600 W	6500 W	5000 W
Rated Voltage	230 V	230 V	230 V	230 V
Rated Frequency	50 Hz	50 Hz	50 Hz	50 Hz
Firmware version	00	00	00	00
Number of phases	Single Phase, L/N/PE	Single Phase, L/N/PE	Single Phase, L/N/PE	Single Phase, L/N/PE
Isolation transformer	NO	NO	NO	NO

Is in compliance with the standard:

- **NRS 097-2-1:2017.**
GRID INTERCONNECTION OF EMBEDDED GENERATION. EDITION 2.1. JULY 2020.
 Part 2: Small-scale embedded generation. Section 1: Utility interface.
 Categories A1 and A2. See exceptions below (*).

Exceptions (*): EMC requirements defined in the clause 4.1.13 of the above-mentioned standard are not included into the scope of compliance of this product certificate.

The above-mentioned generating units are certified according the SGS internal procedure PE.T-ECPE-39 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is valid until: 21st of December of 2023. This certificate is first issued on: 21st of December of 2020.

Madrid, 21st of December of 2020

Daniel Arranz Muñiz
 Certification Manager

